



UL Product iQ
UL'S NEXT GENERATION CERTIFICATIONS SEARCH
 The same trusted data in a modern search engine.

NOW AVAILABLE

▶ LEARN MORE

WYMV7.E241462

Telemetering Equipment for Use in Hazardous Locations Certified for Canada

[Page Bottom](#)

Telemetering Equipment for Use in Hazardous Locations Certified for Canada

[See General Information for Telemetering Equipment for Use in Hazardous Locations Certified for Canada](#)

CIDRA CORPORATE SERVICES INC

E241462

50 BARNES PARK N
 WALLINGFORD, CT 06492 USA

Class I, Division 2, Groups A, B, C and D, Sonartrac flow monitoring system, associated nonincendive field wiring apparatus, transmitters, Model(s) TB8, followed by -xx, where xx may be any alphanumeric combination, followed by -x5 or -x6, where x can be any alphanumeric, followed by -x, where x can be any alphanumeric except 0 or 1, followed by -02 for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations Providing Nonincendive Field Circuits for use in Class I, Division 2, Groups A, B, C and D when connected per control drawing No. 20944-01C.

TB8, followed by -xx, where xx may be any alphanumeric combination, followed by -x5 or -x6, where x can be any alphanumeric, followed by -x, where x can be any alphanumeric, followed by x, where x can be any alphanumeric except 0 or 1, followed by -05 for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations when connected per control drawing No. 20945-01C.

Class I, Division 2, Groups A, B, C and D, Sonartrac flow monitoring system, associated nonincendive field wiring apparatus, transmitters, Model(s) TB8 followed by -xx, where x may be any alphanumeric combination, followed by -03 or -04, for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations Providing Nonincendive Field Circuits for use in Class I, Division 2, Groups A, B, C and D when connected per control drawing No 20332-01

TB8-xx-xx-xy, where x may be any alphanumeric combination, and y may be 0 or 1, followed by -02, for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations Providing Nonincendive Field Circuits for use in Class I, Division 2, Groups A, B, C and D when connected per control drawing No 20332-01.

Class I, Division 2, Groups A, B, C and D, Sonartrac flow monitoring system, nonincendive field wiring apparatus, sensor heads, Model(s) SH, followed by xxx-xx-xx, where x may be any alphanumeric combination, for use in Class I, Division 2, Groups A, B, C and D when connected per control drawing No 20332-01

SH, followed by xxx-xx-xx-xxx, where x may be any alphanumeric, followed by -02, for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations when connected per control drawing No 20944-01C.

SH-xxx-xx-xx-xxx, where x may be any alphanumeric combination, followed by -02, for use in Class I, Division 2, Groups A, B, C and D when connected per control drawing No 20332-01

[Last Updated](#) on 2016-06-27

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".